

Charles A. Castle Associate General Counsel

> Duke Energy 550 South Tryon Street Charlotte, NC 28202

Mailing Address: DEC45A / P.O. Box 1321 Charlotte, NC 28201

> o: 704.382.4499 f_ 980.373.8534

alex.castle@duke-energy.com

August 30, 2016

VIA ELECTRONIC FILING

The Honorable Jocelyn G. Boyd Chief Clerk/Administrator Public Service Commission of South Carolina 101 Executive Center Drive, Suite 100 Columbia, South Carolina 29210

Re: Duke Energy Progress, LLC – Monthly Power Plant Performance

Report

Docket No. 2006-224-E

Dear Mrs. Boyd:

Pursuant to the Commission's Orders in Docket No. 1977-354-E, enclosed for filing is the Monthly Power Plant Performance Report in Docket No. 2006-224-E for the month of July 2016.

Should you have any questions regarding this matter, please do not hesitate to contact me at 704.382.4499.

Sincerely.

Charles A. Castle

Enclosure

cc: Ms. Dawn Hipp, Office of Regulatory Staff

Mr. Jeffrey M. Nelson, Office of Regulatory Staff

Ms. Shannon Bowyer Hudson, Office of Regulatory Staff

Ms. Nanette Edwards, Office of Regulatory Staff

Michael Seaman-Huynh, Office of Regulatory Staff

Ms. Heather Shirley Smith, Duke Energy

Mr. Scott Elliott, Elliott & Elliott, P.A.

Mr. Garrett Stone, Brickfield, Burchette, Ritts & Stone, PC

Mr. Gary Walsh, Walsh Consulting, LLC

| Period: | July, 2016 | |
|----------|------------|--|
| I CIIOU. | oury, =010 | |

| Station | Unit | Date of Outage | Duration of Outage | Scheduled / Unscheduled | Cause of Outage | Reason Outage Occurred | Remedial Action Taken |
|-----------|------|-------------------|-----------------------|----------------------------|-----------------|------------------------|-----------------------|
| Brunswick | 1 | None | | | | | |
| | 2 | None | | | | | |
| Harris | 1 | None | | | | | |
| Robinson | 2 | None | | | | | |

Lee Energy Complex

| Unit | Duration of Outage | Type of Outage | Cause | of Outage | Reason Outage Occurred | Remedial Action Taken |
|------|---|----------------|-------|--|---|--------------------------|
| 1A | 7/10/2016 9:40:00 AM To 7/13/2016 12:47:00 PM | Unsch | 4520 | Gen. Stator Windings; Bushings; And Terminals | Generator lockout due to 64G Relay(Generator Ground). | |

Mayo Station

No Outages at Baseload Units During the Month.

Richmond County Station

| | | | | • | | |
|------|---|----------------|-------|--|--|--------------------------|
| Unit | Duration of Outage | Type of Outage | Cause | of Outage | Reason Outage Occurred | Remedial Action Taken |
| 7 | 7/3/2016 9:54:00 PM To 7/4/2016 9:41:00 PM | Unsch | 5009 | Other Gas Turbine Inlet Air Problems | Inlet Bleed Heat drain valve grounded MK6 system | |
| 8 | 6/30/2016 6:13:00 PM To 7/1/2016 7:39:00 PM | Unsch | 5120 | Gas Turbine - Hydraulic Oil System | Hydraulic filter casing failed. | |
| | | | Rox | boro Station | | |
| Unit | Duration of Outage | Type of Outage | Cause | of Outage | Reason Outage Occurred | Remedial Action Taken |
| 4 | 7/18/2016 3:06:00 AM To 7/18/2016 5:26:00 AM | Unsch | 3149 | Condenser Loss of Vacuum | Turbine Trip to Low Condenser Vacuum | |

Sutton Energy Complex

No Outages at Baseload Units During the Month.

July 2016 **Brunswick Nuclear Station**

| | Unit | 1 | Unit | 2 |
|---|---------|---------|---------|---------|
| (A) MDC (mW) | 938 | | 932 | |
| (B) Period Hours | 744 | | 744 | |
| (C) Net Gen (mWh) and Capacity Factor (%) | 704,133 | 100.90 | 678,410 | 97.84 |
| (D) Net mWh Not Gen due to Full Schedule Outages | 0 | 0.00 | 0 | 0.00 |
| * (E) Net mWh Not Gen due to Partial Scheduled Outages | 0 | 0.00 | 0 | 0.00 |
| (F) Net mWh Not Gen due to Full Forced Outages | 0 | 0.00 | 0 | 0.00 |
| * (G) Net mWh Not Gen due to Partial Forced Outages | -6,261 | -0.90 | 14,998 | 2.16 |
| * (H) Net mWh Not Gen due to Economic Dispatch | 0 | 0.00 | 0 | 0.00 |
| * (I) Core Conservation | 0 | 0.00 | 0 | 0.00 |
| (J) Net mWh Possible in Period | 697,872 | 100.00% | 693,408 | 100.00% |
| (K) Equivalent Availability (%) | | 100.00 | | 99.58 |
| (L) Output Factor (%) | | 100.90 | | 97.84 |
| (M) Heat Rate (BTU/NkWh) | | 10,260 | | 10,512 |

July 2016 **Harris Nuclear Station**

| | Unit | <u>1</u> |
|---|---------|----------|
| (A) MDC (mW) | 928 | |
| (B) Period Hours | 744 | |
| () | | |
| (C) Net Gen (mWh) and Capacity Factor (%) | 695,043 | 100.67 |
| (D) Net mWh Not Gen due to Full Schedule Outages | 0 | 0.00 |
| * (E) Net mWh Not Gen due to Partial Scheduled Outages | 0 | 0.00 |
| (F) Net mWh Not Gen due to Full Forced Outages | 0 | 0.00 |
| * (G) Net mWh Not Gen due to Partial Forced Outages | -4,611 | -0.67 |
| * (H) Net mWh Not Gen due to Economic Dispatch | 0 | 0.00 |
| * (I) Core Conservation | 0 | 0.00 |
| (J) Net mWh Possible in Period | 690,432 | 100.00% |
| (K) Equivalent Availability (%) | | 100.00 |
| (L) Output Factor (%) | | 100.67 |

10,557

(M) Heat Rate (BTU/NkWh)

July 2016 **Robinson Nuclear Station**

| | Unit 2 | • |
|---|------------------|---------|
| (A) MDC (mW) | 741 | |
| (B) Period Hours | 744 | |
| (D) I CHOU HOURS | / 1 1 | |
| (C) Net Gen (mWh) and Capacity Factor (%) | 551,596 | 100.05 |
| (D) Net mWh Not Gen due to Full Schedule Outages | 0 | 0.00 |
| * (E) Net mWh Not Gen due to Partial Scheduled Outages | 0 | 0.00 |
| (F) Net mWh Not Gen due to Full Forced Outages | 0 | 0.00 |
| * (G) Net mWh Not Gen due to Partial Forced Outages | -292 | -0.05 |
| * (H) Net mWh Not Gen due to Economic Dispatch | 0 | 0.00 |
| * (I) Core Conservation | 0 | 0.00 |
| (J) Net mWh Possible in Period | 551,304 | 100.00% |
| (K) Equivalent Availability (%) | | 100.00 |
| (L) Output Factor (%) | | 100.05 |
| (M) Heat Rate (BTU/NkWh) | | 10,754 |

Lee Energy Complex

| | Unit 1A | Unit 1B | Unit 1C | Unit ST1 | Block Total |
|--|---------|---------|---------|----------|-------------|
| (A) MDC (mW) | 177 | 176 | 179 | 378 | 910 |
| (B) Period Hrs | 744 | 744 | 744 | 744 | 744 |
| (C) Net Generation (mWh) | 109,301 | 123,418 | 124,515 | 249,822 | 607,056 |
| (D) Capacity Factor (%) | 83.00 | 94.25 | 93.50 | 88.83 | 89.66 |
| (E) Net mWh Not Generated due to Full Scheduled Outages | 0 | 0 | 0 | 0 | 0 |
| (F) Scheduled Outages: percent of Period Hrs | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| (G) Net mWh Not Generated due to Partial Scheduled Outages | 0 | 0 | 0 | 0 | 0 |
| (H) Scheduled Derates: percent of Period Hrs | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| (I) Net mWh Not Generated due to Full Forced Outages | 13,296 | 0 | 0 | 0 | 13,296 |
| (J) Forced Outages: percent of Period Hrs | 10.10 | 0.00 | 0.00 | 0.00 | 1.96 |
| (K) Net mWh Not Generated due to Partial Forced Outages | 0 | 0 | 0 | 7,136 | 7,136 |
| (L) Forced Derates: percent of Period Hrs | 0.00 | 0.00 | 0.00 | 2.54 | 1.05 |
| (M) Net mWh Not Generated due to Economic Dispatch | 9,091 | 7,526 | 8,661 | 24,274 | 49,552 |
| (N) Economic Dispatch: percent of Period Hrs | 6.90 | 5.75 | 6.50 | 8.63 | 7.32 |
| (O) Net mWh Possible in Period | 131,688 | 130,944 | 133,176 | 281,232 | 677,040 |
| (P) Equivalent Availability (%) | 89.90 | 100.00 | 100.00 | 97.46 | 96.98 |
| (Q) Output Factor (%) | 92.32 | 94.25 | 93.50 | 88.83 | 91.46 |
| (R) Heat Rate (BTU/NkWh) | 9,208 | 9,160 | 9,060 | 4,511 | 7,235 |

Richmond County Station

| | Unit 7 | Unit 8 | Unit ST4 | Block Total |
|--|---------|---------|----------|-------------|
| (A) MDC (mW) | 160 | 157 | 165 | 482 |
| (B) Period Hrs | 744 | 744 | 744 | 744 |
| (C) Net Generation (mWh) | 105,519 | 104,447 | 123,932 | 333,898 |
| (D) Capacity Factor (%) | 88.64 | 89.42 | 100.95 | 93.11 |
| (E) Net mWh Not Generated due to Full Scheduled Outages | 0 | 0 | 0 | 0 |
| (F) Scheduled Outages: percent of Period Hrs | 0.00 | 0.00 | 0.00 | 0.00 |
| (G) Net mWh Not Generated due to Partial Scheduled Outages | 0 | 0 | 0 | 0 |
| (H) Scheduled Derates: percent of Period Hrs | 0.00 | 0.00 | 0.00 | 0.00 |
| (I) Net mWh Not Generated due to Full Forced Outages | 3,805 | 3,085 | 0 | 6,890 |
| (J) Forced Outages: percent of Period Hrs | 3.20 | 2.64 | 0.00 | 1.92 |
| (K) Net mWh Not Generated due to Partial Forced Outages | 0 | 0 | 3,257 | 3,257 |
| (L) Forced Derates: percent of Period Hrs | 0.00 | 0.00 | 2.65 | 0.91 |
| (M) Net mWh Not Generated due to Economic Dispatch | 9,716 | 9,276 | 0 | 18,992 |
| (N) Economic Dispatch: percent of Period Hrs | 8.16 | 7.94 | 0.00 | 5.30 |
| (O) Net mWh Possible in Period | 119,040 | 116,808 | 122,760 | 358,608 |
| (P) Equivalent Availability (%) | 96.80 | 97.36 | 97.35 | 97.17 |
| (Q) Output Factor (%) | 92.53 | 93.40 | 100.95 | 95.77 |
| (R) Heat Rate (BTU/NkWh) | 11,703 | 11,477 | 0 | 7,288 |

Richmond County Station

| | Unit 9 | Unit 10 | Unit ST5 | Block Total |
|--|---------|---------|----------|-------------|
| (A) MDC (mW) | 178 | 178 | 250 | 606 |
| (B) Period Hrs | 744 | 744 | 744 | 744 |
| (C) Net Generation (mWh) | 124,839 | 126,171 | 178,810 | 429,820 |
| (D) Capacity Factor (%) | 94.27 | 95.27 | 96.13 | 95.33 |
| (E) Net mWh Not Generated due to Full Scheduled Outages | 0 | 0 | 0 | 0 |
| (F) Scheduled Outages: percent of Period Hrs | 0.00 | 0.00 | 0.00 | 0.00 |
| (G) Net mWh Not Generated due to Partial Scheduled Outages | 0 | 0 | 0 | 0 |
| (H) Scheduled Derates: percent of Period Hrs | 0.00 | 0.00 | 0.00 | 0.00 |
| (I) Net mWh Not Generated due to Full Forced Outages | 0 | 0 | 0 | 0 |
| (J) Forced Outages: percent of Period Hrs | 0.00 | 0.00 | 0.00 | 0.00 |
| (K) Net mWh Not Generated due to Partial Forced Outages | 0 | 0 | 0 | 0 |
| (L) Forced Derates: percent of Period Hrs | 0.00 | 0.00 | 0.00 | 0.00 |
| (M) Net mWh Not Generated due to Economic Dispatch | 7,593 | 6,261 | 7,190 | 21,044 |
| (N) Economic Dispatch: percent of Period Hrs | 5.73 | 4.73 | 3.87 | 4.67 |
| (O) Net mWh Possible in Period | 132,432 | 132,432 | 186,000 | 450,864 |
| (P) Equivalent Availability (%) | 100.00 | 100.00 | 100.00 | 100.00 |
| (Q) Output Factor (%) | 94.27 | 95.27 | 96.13 | 95.33 |
| (R) Heat Rate (BTU/NkWh) | 11,748 | 11,583 | 0 | 6,812 |

Roxboro Station

| | Unit 2 |
|--|---------|
| (A) MDC (mW) | 671 |
| (B) Period Hrs | 744 |
| (C) Net Generation (mWh) | 416,939 |
| (D) Capacity Factor (%) | 83.52 |
| (E) Net mWh Not Generated due to Full Scheduled Outages | 0 |
| (F) Scheduled Outages: percent of Period Hrs | 0.00 |
| (G) Net mWh Not Generated due to Partial Scheduled Outages | 2,226 |
| (H) Scheduled Derates: percent of Period Hrs | 0.45 |
| (I) Net mWh Not Generated due to Full Forced Outages | 0 |
| (J) Forced Outages: percent of Period Hrs | 0.00 |
| (K) Net mWh Not Generated due to Partial Forced Outages | 0 |
| (L) Forced Derates: percent of Period Hrs | 0.00 |
| (M) Net mWh Not Generated due to Economic Dispatch | 80,059 |
| (N) Economic Dispatch: percent of Period Hrs | 16.04 |
| (O) Net mWh Possible in Period | 499,224 |
| (P) Equivalent Availability (%) | 99.55 |
| (Q) Output Factor (%) | 83.52 |
| (R) Heat Rate (BTU/NkWh) | 10,022 |

Sutton Energy Complex

| | Unit 1A | Unit 1B | Unit ST1 | Block Total |
|--|---------|---------|----------|-------------|
| (A) MDC (mW) | 179 | 179 | 264 | 622 |
| (B) Period Hrs | 744 | 744 | 744 | 744 |
| (C) Net Generation (mWh) | 122,651 | 123,458 | 167,956 | 414,065 |
| (D) Capacity Factor (%) | 92.10 | 92.70 | 85.51 | 89.48 |
| (E) Net mWh Not Generated due to Full Scheduled Outages | 0 | 0 | 0 | 0 |
| (F) Scheduled Outages: percent of Period Hrs | 0.00 | 0.00 | 0.00 | 0.00 |
| (G) Net mWh Not Generated due to Partial Scheduled Outages | 0 | 0 | 0 | 0 |
| (H) Scheduled Derates: percent of Period Hrs | 0.00 | 0.00 | 0.00 | 0.00 |
| (I) Net mWh Not Generated due to Full Forced Outages | 0 | 0 | 0 | 0 |
| (J) Forced Outages: percent of Period Hrs | 0.00 | 0.00 | 0.00 | 0.00 |
| (K) Net mWh Not Generated due to Partial Forced Outages | 0 | 0 | 0 | 0 |
| (L) Forced Derates: percent of Period Hrs | 0.00 | 0.00 | 0.00 | 0.00 |
| (M) Net mWh Not Generated due to Economic Dispatch | 10,525 | 9,718 | 28,460 | 48,703 |
| (N) Economic Dispatch: percent of Period Hrs | 7.90 | 7.30 | 14.49 | 10.52 |
| (O) Net mWh Possible in Period | 133,176 | 133,176 | 196,416 | 462,768 |
| (P) Equivalent Availability (%) | 100.00 | 100.00 | 100.00 | 100.00 |
| (Q) Output Factor (%) | 92.10 | 92.70 | 85.51 | 89.48 |
| (R) Heat Rate (BTU/NkWh) | 11,995 | 11,884 | 0 | 7,096 |

Duke Energy Progress Intermediate Power Plant Performance Review Plan July 2016

Mayo Station

| | | Unit 1 |
|--------------|-----------------------------|---------|
| (A) | MDC (mW) | 727 |
| (B) | Period Hrs | 744 |
| (C) | Net Generation (mWh) | 321,702 |
| (D) | Net mWh Possible in Period | 540,888 |
| (E) | Equivalent Availability (%) | 92.85 |
| (F) | Output Factor (%) | 59.48 |
| (G) | Capacity Factor (%) | 59.48 |

Duke Energy Progress Intermediate Power Plant Performance Review Plan July 2016

Roxboro Station

| | | Unit 3 | Unit 4 |
|------------|-----------------------------|---------|---------|
| (A) | MDC (mW) | 691 | 698 |
| (B) | Period Hrs | 744 | 744 |
| (C) | Net Generation (mWh) | 401,392 | 365,322 |
| (D) | Net mWh Possible in Period | 514,104 | 519,312 |
| (E) | Equivalent Availability (%) | 99.49 | 87.71 |
| (F) | Output Factor (%) | 78.08 | 70.57 |
| (G) | Capacity Factor (%) | 78.08 | 70.35 |

August 2015 - July 2016 **Brunswick Nuclear Station**

| | Unit | 1 | Unit | 2 |
|---|-----------|---------|-----------|---------|
| (A) MDC (mW) | 938 | | 932 | |
| (B) Period Hours | 8784 | | 8784 | |
| (C) Net Gen (mWh) and Capacity Factor (%) | 7,248,288 | 87.97 | 8,138,729 | 99.41 |
| (D) Net mWh Not Gen due to Full Schedule Outages | 709,034 | 8.61 | 0 | 0.00 |
| * (E) Net mWh Not Gen due to Partial Scheduled Outages | 166,461 | 2.02 | 41,660 | 0.51 |
| (F) Net mWh Not Gen due to Full Forced Outages | 165,979 | 2.01 | 0 | 0.00 |
| * (G) Net mWh Not Gen due to Partial Forced Outages | -50,370 | -0.61 | 6,299 | 0.08 |
| * (H) Net mWh Not Gen due to Economic Dispatch | 0 | 0.00 | 0 | 0.00 |
| * (I) Core Conservation | 0 | 0.00 | 0 | 0.00 |
| (J) Net mWh Possible in Period | 8,239,392 | 100.00% | 8,186,688 | 100.00% |
| (K) Equivalent Availability (%) | | 87.77 | | 99.48 |
| (L) Output Factor (%) | | 98.42 | | 99.41 |
| (M) Heat Rate (BTU/NkWh) | | 10,347 | | 10,550 |

August 2015 - July 2016 **Harris Nuclear Station**

Unit 1

| (A) MDC (mW) | 928 | | |
|---|-----------|---------|--|
| (B) Period Hours | 8784 | | |
| (C) Net Gen (mWh) and Capacity Factor (%) | 8,346,240 | 102.39 | |
| (D) Net mWh Not Gen due to Full Schedule Outages | 0 | 0.00 | |
| * (E) Net mWh Not Gen due to Partial Scheduled Outages | 5,461 | 0.07 | |
| (F) Net mWh Not Gen due to Full Forced Outages | 0 | 0.00 | |
| * (G) Net mWh Not Gen due to Partial Forced Outages | -200,149 | -2.46 | |
| * (H) Net mWh Not Gen due to Economic Dispatch | 0 | 0.00 | |
| * (I) Core Conservation | 0 | 0.00 | |
| (J) Net mWh Possible in Period | 8,151,552 | 100.00% | |
| (K) Equivalent Availability (%) | | 99.82 | |
| (L) Output Factor (%) | | 102.39 | |
| (M) Heat Rate (BTU/NkWh) | | 10,289 | |

August 2015 - July 2016 **Robinson Nuclear Station**

| | Unit | 2 |
|---|-----------|---------|
| (A) MDC (mW) | 741 | |
| (B) Period Hours | 8784 | |
| (C) Net Gen (mWh) and Capacity Factor (%) | 6,543,384 | 100.53 |
| (D) Net mWh Not Gen due to Full Schedule Outages | 210,531 | 3.23 |
| * (E) Net mWh Not Gen due to Partial Scheduled Outages | 2,112 | 0.03 |
| (F) Net mWh Not Gen due to Full Forced Outages | 0 | 0.00 |
| * (G) Net mWh Not Gen due to Partial Forced Outages | -247,083 | -3.79 |
| * (H) Net mWh Not Gen due to Economic Dispatch | 0 | 0.00 |
| * (I) Core Conservation | 0 | 0.00 |
| (J) Net mWh Possible in Period | 6,508,944 | 100.00% |
| (K) Equivalent Availability (%) | | 96.48 |
| (L) Output Factor (%) | | 103.89 |

10,337

(M) Heat Rate (BTU/NkWh)

Lee Energy Complex

| | Unit 1A | Unit 1B | Unit 1C | Unit ST1 | Block Total |
|--|-----------|-----------|-----------|-----------|-------------|
| (A) MDC (mW) | 196 | 195 | 197 | 378 | 967 |
| (B) Period Hrs | 8,784 | 8,784 | 8,784 | 8,784 | 8,784 |
| (C) Net Generation (mWh) | 1,325,648 | 1,350,068 | 1,378,389 | 2,533,237 | 6,587,342 |
| (D) Capacity Factor (%) | 76.96 | 78.78 | 79.54 | 76.21 | 77.56 |
| (E) Net mWh Not Generated due to Full Scheduled Outages | 95,205 | 109,884 | 70,381 | 465,227 | 740,697 |
| (F) Scheduled Outages: percent of Period Hrs | 5.53 | 6.41 | 4.06 | 14.00 | 8.72 |
| (G) Net mWh Not Generated due to Partial Scheduled Outages | 0 | 0 | 0 | 56,863 | 56,863 |
| (H) Scheduled Derates: percent of Period Hrs | 0.00 | 0.00 | 0.00 | 1.71 | 0.67 |
| (I) Net mWh Not Generated due to Full Forced Outages | 34,196 | 9,102 | 1,570 | 0 | 44,868 |
| (J) Forced Outages: percent of Period Hrs | 1.99 | 0.53 | 0.09 | 0.00 | 0.53 |
| (K) Net mWh Not Generated due to Partial Forced Outages | 0 | 0 | 0 | 21,246 | 21,246 |
| (L) Forced Derates: percent of Period Hrs | 0.00 | 0.00 | 0.00 | 0.64 | 0.25 |
| (M) Net mWh Not Generated due to Economic Dispatch | 267,527 | 244,738 | 282,509 | 247,427 | 1,042,201 |
| (N) Economic Dispatch: percent of Period Hrs | 15.53 | 14.28 | 16.30 | 7.44 | 12.27 |
| (O) Net mWh Possible in Period | 1,722,576 | 1,713,792 | 1,732,848 | 3,324,000 | 8,493,216 |
| (P) Equivalent Availability (%) | 92.15 | 93.04 | 95.87 | 83.66 | 89.83 |
| (Q) Output Factor (%) | 87.51 | 88.59 | 88.89 | 88.61 | 88.44 |
| (R) Heat Rate (BTU/NkWh) | 9,339 | 9,342 | 9,198 | 4,190 | 7,330 |

Richmond County Station

| | Unit 7 | Unit 8 | Unit ST4 | Block Total |
|--|-----------|-----------|-----------|-------------|
| (A) MDC (mW) | 172 | 170 | 169 | 512 |
| (B) Period Hrs | 8,784 | 8,784 | 8,784 | 8,784 |
| (C) Net Generation (mWh) | 1,243,052 | 1,232,522 | 1,399,195 | 3,874,769 |
| (D) Capacity Factor (%) | 82.25 | 82.40 | 94.17 | 86.24 |
| (E) Net mWh Not Generated due to Full Scheduled Outages | 112,480 | 97,214 | 95,194 | 304,888 |
| (F) Scheduled Outages: percent of Period Hrs | 7.44 | 6.50 | 6.41 | 6.79 |
| (G) Net mWh Not Generated due to Partial Scheduled Outages | 0 | 0 | 16,122 | 16,122 |
| (H) Scheduled Derates: percent of Period Hrs | 0.00 | 0.00 | 1.09 | 0.36 |
| (I) Net mWh Not Generated due to Full Forced Outages | 4,138 | 12,134 | 1,793 | 18,065 |
| (J) Forced Outages: percent of Period Hrs | 0.27 | 0.81 | 0.12 | 0.40 |
| (K) Net mWh Not Generated due to Partial Forced Outages | 0 | 0 | 3,974 | 3,974 |
| (L) Forced Derates: percent of Period Hrs | 0.00 | 0.00 | 0.27 | 0.09 |
| (M) Net mWh Not Generated due to Economic Dispatch | 151,562 | 153,954 | 0 | 275,079 |
| (N) Economic Dispatch: percent of Period Hrs | 10.03 | 10.29 | 0.00 | 6.12 |
| (O) Net mWh Possible in Period | 1,511,232 | 1,495,824 | 1,485,840 | 4,492,896 |
| (P) Equivalent Availability (%) | 91.70 | 92.13 | 91.92 | 92.36 |
| (Q) Output Factor (%) | 89.21 | 89.76 | 100.74 | 93.25 |
| (R) Heat Rate (BTU/NkWh) | 11,449 | 10,114 | 0 | 6,890 |

Richmond County Station

| | Unit 9 | Unit 10 | Unit ST5 | Block Total |
|--|-----------|-----------|-----------|-------------|
| (A) MDC (mW) | 193 | 193 | 248 | 634 |
| (B) Period Hrs | 8,784 | 8,784 | 8,784 | 8,784 |
| (C) Net Generation (mWh) | 1,419,372 | 1,421,419 | 1,855,221 | 4,696,012 |
| (D) Capacity Factor (%) | 83.74 | 83.87 | 85.05 | 84.29 |
| (E) Net mWh Not Generated due to Full Scheduled Outages | 107,805 | 110,090 | 194,388 | 412,283 |
| (F) Scheduled Outages: percent of Period Hrs | 6.36 | 6.50 | 8.91 | 7.40 |
| (G) Net mWh Not Generated due to Partial Scheduled Outages | 0 | 0 | 0 | 0 |
| (H) Scheduled Derates: percent of Period Hrs | 0.00 | 0.00 | 0.00 | 0.00 |
| (I) Net mWh Not Generated due to Full Forced Outages | 3,563 | 8,036 | 40,164 | 51,763 |
| (J) Forced Outages: percent of Period Hrs | 0.21 | 0.47 | 1.84 | 0.93 |
| (K) Net mWh Not Generated due to Partial Forced Outages | 0 | 0 | 216 | 216 |
| (L) Forced Derates: percent of Period Hrs | 0.00 | 0.00 | 0.01 | 0.00 |
| (M) Net mWh Not Generated due to Economic Dispatch | 164,140 | 155,334 | 91,419 | 410,894 |
| (N) Economic Dispatch: percent of Period Hrs | 9.68 | 9.16 | 4.19 | 7.38 |
| (O) Net mWh Possible in Period | 1,694,880 | 1,694,880 | 2,181,408 | 5,571,168 |
| (P) Equivalent Availability (%) | 93.65 | 93.32 | 89.18 | 91.67 |
| (Q) Output Factor (%) | 92.71 | 93.31 | 96.50 | 94.36 |
| (R) Heat Rate (BTU/NkWh) | 11,496 | 11,420 | 0 | 6,931 |

Roxboro Station

| | Unit 2 |
|--|-----------|
| (A) MDC (mW) | 672 |
| (B) Period Hrs | 8,784 |
| (C) Net Generation (mWh) | 2,828,090 |
| (D) Capacity Factor (%) | 47.92 |
| (E) Net mWh Not Generated due to Full Scheduled Outages | 572,905 |
| (F) Scheduled Outages: percent of Period Hrs | 9.71 |
| (G) Net mWh Not Generated due to Partial Scheduled Outages | 4,275 |
| (H) Scheduled Derates: percent of Period Hrs | 0.07 |
| (I) Net mWh Not Generated due to Full Forced Outages | 69,741 |
| (J) Forced Outages: percent of Period Hrs | 1.18 |
| (K) Net mWh Not Generated due to Partial Forced Outages | 1,169 |
| (L) Forced Derates: percent of Period Hrs | 0.02 |
| (M) Net mWh Not Generated due to Economic Dispatch | 2,425,181 |
| (N) Economic Dispatch: percent of Period Hrs | 41.10 |
| (O) Net mWh Possible in Period | 5,901,360 |
| (P) Equivalent Availability (%) | 89.03 |
| (Q) Output Factor (%) | 68.83 |
| (R) Heat Rate (BTU/NkWh) | 10,332 |

Sutton Energy Complex

| | Unit 1A | Unit 1B | Unit ST1 | Block Total |
|--|-----------|-----------|-----------|-------------|
| (A) MDC (mW) | 198 | 198 | 265 | 662 |
| (B) Period Hrs | 8,784 | 8,784 | 8,784 | 8,784 |
| (C) Net Generation (mWh) | 1,336,039 | 1,404,936 | 1,694,192 | 4,435,167 |
| (D) Capacity Factor (%) | 76.78 | 80.74 | 72.71 | 76.33 |
| (E) Net mWh Not Generated due to Full Scheduled Outages | 131,394 | 101,983 | 65,547 | 298,923 |
| (F) Scheduled Outages: percent of Period Hrs | 7.55 | 5.86 | 2.81 | 5.14 |
| (G) Net mWh Not Generated due to Partial Scheduled Outages | 0 | 0 | 111,367 | 111,367 |
| (H) Scheduled Derates: percent of Period Hrs | 0.00 | 0.00 | 4.78 | 1.92 |
| (I) Net mWh Not Generated due to Full Forced Outages | 173 | 1,814 | 2,578 | 4,566 |
| (J) Forced Outages: percent of Period Hrs | 0.01 | 0.10 | 0.11 | 0.08 |
| (K) Net mWh Not Generated due to Partial Forced Outages | 0 | 0 | 0 | 0 |
| (L) Forced Derates: percent of Period Hrs | 0.00 | 0.00 | 0.00 | 0.00 |
| (M) Net mWh Not Generated due to Economic Dispatch | 272,538 | 231,411 | 456,236 | 960,185 |
| (N) Economic Dispatch: percent of Period Hrs | 15.66 | 13.30 | 19.58 | 16.53 |
| (O) Net mWh Possible in Period | 1,740,144 | 1,740,144 | 2,329,920 | 5,810,208 |
| (P) Equivalent Availability (%) | 93.10 | 93.70 | 92.30 | 92.86 |
| (Q) Output Factor (%) | 87.06 | 87.75 | 76.28 | 82.80 |
| (R) Heat Rate (BTU/NkWh) | 11,440 | 11,342 | 0 | 7,039 |

Mayo Station

| Unit | s | Unit 1 |
|--------------|-----------------------------|-----------|
| (A) | MDC (mW) | 735 |
| (B) | Period Hrs | 8,784 |
| (C) | Net Generation (mWh) | 1,892,001 |
| (D) | Net mWh Possible in Period | 6,455,280 |
| (E) | Equivalent Availability (%) | 86.43 |
| (F) | Output Factor (%) | 51.63 |
| (G) | Capacity Factor (%) | 29.31 |

Roxboro Station

| Unit | s | Unit 3 | Unit 4 |
|------------|------------------------------------|-----------|-----------|
| (A) | MDC (mW) | 694 | 703 |
| (B) | Period Hrs | 8,784 | 8,784 |
| (C) | Net Generation (mWh) | 1,519,567 | 1,637,527 |
| (D) | Net mWh Possible in Period | 6,095,280 | 6,178,656 |
| (E) | Equivalent Availability (%) | 70.83 | 88.16 |
| (F) | Output Factor (%) | 61.99 | 68.03 |
| (G) | Capacity Factor (%) | 24.93 | 26.50 |

Page 23 of 25

Duke Energy Progress Outages for 100 mW or Larger Units July, 2016

Full Outage Hours

| Unit Name | Capacity Rating (mW) | Scheduled | Unscheduled | Total | |
|--------------|----------------------|-----------|-------------|-------|--|
| Brunswick 1 | 938 | 0.00 | 0.00 | 0.00 | |
| Brunswick 2 | 932 | 0.00 | 0.00 | 0.00 | |
| | | | | | |
| Harris 1 | 928 | 0.00 | 0.00 | 0.00 | |
| | | | | | |
| Robinson 2 | 741 | 0.00 | 0.00 | 0.00 | |
| | | | | | |

Duke Energy Progress Outages for 100 mW or Larger Units July 2016

| | Capacity | Full Ou | Full Outage Hours | | |
|---------------------------|-------------|-----------------------|-------------------|-----------------------|--|
| Unit Name | Rating (mW) | Scheduled Unscheduled | | Total Outage Hours | |
| Asheville Steam 1 | 189 | 0.00 | 84.42 | 84.42 | |
| Asheville Steam 2 | 189 | 0.00 | 5.38 | 5.38 | |
| Asheville CT 3 | 164 | 0.00 | 0.00 | 0.00 | |
| Asheville CT 4 | 160 | 0.00 | 0.00 | 0.00 | |
| Darlington CT 12 | 118 | 0.00 | 65.00 | 65.00 | |
| Darlington CT 13 | 116 | 32.78 | 15.83 | 48.62 | |
| Lee Energy Complex CC 1A | 177 | 0.00 | 75.12 | 75.12 | |
| Lee Energy Complex CC 1B | 176 | 0.00 | 0.00 | 0.00 | |
| Lee Energy Complex CC 1C | 179 | 0.00 | 0.00 | 0.00 | |
| Lee Energy Complex CC ST1 | 378 | 0.00 | 0.00 | 0.00 | |
| Mayo Steam 1 | 727 | 0.00 | 0.00 | 0.00 | |
| Richmond County CC 1 | 157 | 0.00 | 2.25 | 2.25 | |
| Richmond County CC 2 | 156 | 0.00 | 0.00 | 0.00 | |
| Richmond County CC 3 | 155 | 0.00 | 0.00 | 0.00 | |
| Richmond County CC 4 | 159 | 0.00 | 0.00 | 0.00 | |
| Richmond County CC 6 | 153 | 0.00 | 0.00 | 0.00 | |
| Richmond County CC 7 | 160 | 0.00 | 23.78 | 23.78 | |
| Richmond County CC 8 | 157 | 0.00 | 19.65 | 19.65 | |
| Richmond County CC ST4 | 165 | 0.00 | 0.00 | 0.00 | |
| Richmond County CC 9 | 178 | 0.00 | 0.00 | 0.00 | |
| Richmond County CC 10 | 178 | 0.00 | 0.00 | 0.00 | |
| Richmond County CC ST5 | 250 | 0.00 | 0.00 | 0.00 | |

Duke Energy Progress Outages for 100 mW or Larger Units July 2016

| | Capacity | Full Ou | Total Outage | |
|------------------------------|-------------|-----------|--------------|-------|
| Unit Name | Rating (mW) | Scheduled | Unscheduled | Hours |
| Roxboro Steam 1 | 379 | 0.10 | 82.47 | 82.57 |
| Roxboro Steam 2 | 671 | 0.00 | 0.00 | 0.00 |
| Roxboro Steam 3 | 691 | 0.00 | 0.00 | 0.00 |
| Roxboro Steam 4 | 698 | 0.00 | 2.33 | 2.33 |
| Sutton Energy Complex CC 1A | 179 | 0.00 | 0.00 | 0.00 |
| Sutton Energy Complex CC 1B | 179 | 0.00 | 0.00 | 0.00 |
| Sutton Energy Complex CC ST1 | 264 | 0.00 | 0.00 | 0.00 |
| Wayne County CT 10 | 177 | 0.00 | 0.00 | 0.00 |
| Wayne County CT 11 | 174 | 0.00 | 0.00 | 0.00 |
| Wayne County CT 12 | 173 | 73.83 | 20.37 | 94.20 |
| Wayne County CT 13 | 170 | 0.00 | 0.00 | 0.00 |
| Wayne County CT 14 | 169 | 0.00 | 14.00 | 14.00 |